

APPENDIX G
DAC INVENTORY & OUTREACH SUMMARY

SR1: Northern Tulare County						Water System			Sewer System			Storm Water and Drainage		Flooding Problems	
Water System	Type	Area Type	School District	Water Provider	Outreach Notes	Type of System	Needs	Notes	Have	Needs	Notes	Have	Needs	Have	Needs
Cutler Elementary School		School	Cutler-Orosi USD	Cutler PUD		Groundwater; community water system	none at this time	NA		NA	NA			NA	NA
Cutler PUD	C	Community		Cutler PUD		Groundwater; community water system	Not enough sectionalizing valves. Need valves installed on Water Distribution System. Currently need to shut down whole system to make repairs.	According to Cutler PUD Manager, Dionicio "Junior" Rodriguez the water distribution system is in dire need of sectionalizing valves in distribution system.	None at this time.	USDA application submitted		unkown		NA	
Delft Colony	C	Community		Tulare County CSA		Groundwater; community water system				NA		unknown		NA	
East Orosi CSD	C	Community		East Orosi CSD		Groundwater; community water system	Water system is high in nitrates. Need to rehabilitate existing wells and/or connect to new supply.	EOCSD has applied for IRWMP grant to rehabilitate East Well.	None at this time	NA	NA	Unknown	seeking funding	Areas floods during storm season.	
El Monte School		School	Cutler-Orosi USD	OROSI PUD		Groundwater; community water system	None at this time	NA	None at this time.	NA	NA	NONE		NA	NA
El Monte Village MHP	C	Private		El Monte Village MHP		Groundwater; community water system	Water system is high in nitrates and the distribution system is old and needs repairs.	Nitrate MCL over 45. Owner recently received notice of Prop 84 funding and reqwuests assistance with planning application.	None at this time	NA	NA	(none)		Do not have drains and therefore area floods during rain season.	
Gleanings for the Hungry	C	Private		Gleanings for the Hungry		Groundwater; community water system	Currently they are "blending" water from Wells #2 and #3 due to capacity limitation in Well #2 and high nitrates in Well #3. Install new well.		Septic system w/leachline currently meeting needs.	NA	NA	Unknown	Seeking state funding.	NA	No problems noted
Grandview School	NTNC	School	Dinuba USD	Dinuba Unified School District		Groundwater; community water system	None at this time	NA	None at this time.	NA	NA	NONE		NA	NA
Griggs Avenue	C	Community		City of Dinuba		connected to city of Dinuba water ssytem.		unable to contact	Septic systems					Area floods during rainy season	would like to seek funding
London CSD	C	Community		London CSD		No water meters on system.	Water system needs to have meters installed.		None at this time.	NA	NA		NA	NA	
Lopez Labor Camp	C	Private		Camp/Cutler PUD		Groundwater; partially tied to Cutler PUD water system; partially served by private well.			NA			NA			
Lovell School	NTNC	School	Cutler-Orosi USD	Cutler-Orosi Unified School District		Groundwater; community water system	None at this time	NA	unknown.	NA	NA	NONE			
Monson		Community		no water system		Served by provate wells	High percentage of provate wells contaminated with nitrate. Currently the community is seeking support from Tulare County to submit a funding application on their behalf to CDPH.	Monson is not a legal entity and thefore is not eligible to apply for funding.	unknown			NA			

SR1: Northern Tulare County						Water System			Sewer System			Storm Water and Drainage		Flooding Problems	
Water System	Type	Area Type	School District	Water Provider	Outreach Notes	Type of System	Needs	Notes	Have	Needs	Notes	Have	Needs	Have	Needs
Norseman MHP	C	Private		Norseman MHP									NA	NA	
Orosi High		School	Cutler-Orosi USD	Orosi High			None at this time	NA	None at this time.	NA	NA	NONE			
Orosi PUD	C	Community		Orosi PUD		Groundwater; community water system			None at this time.	NA	NA	None at this time		NA	NA
Palm School		School					None at this time	NA	None at this time.	NA	NA	NONE		NA	NA
Seville	C	Community		County of Tulare as Receiver		Seville's community water system is currently under receivership with the County of Tulare.	Water system is high in nitrates.	County of Tulare received CDPH Prop 84 Planning Grant for Yettem and Seville						Potion of community flooded a couple of years ago	Need to direct Sontag Ditch water away from community...possibly into Stone Corral Drainage Ditch
Stone Corral Elementary School	C	School	Stone Corral Elementary SD	Stone Corral Elementary School District		Water system high in nitrates.	The schools water is high in nitrates and the distribution system needs repair.	The County of Tulare has has submitted a Prop 84 planning application on behalf of the community of Seville which includes the school.	None at this time.	NA	NA	NONE		School flooded a couple of years ago	Need to direct Sontag Ditch water away from community...possibly into Stone Corral Drainage Ditch
Sultana CSD	C	Community		Sultana CSD		Groundwater; community water system	Backup well exceeds DBCP MCL. System needs a second source of potable water.							(none)	(none)
Traver	C	Community		California Water Services		Groundwater; community water system									
Traver Joint Elementary School	C	School	Traver Joint Elementary School	Traver Water system by California Water Services		Groundwater; community water system	None at this time		Unknown	NA	NA	None		NA	NA
Yettem	C	Community		Tulare County CSA		Groundwater; community water system	One well at times exceeds nitrate MCL. Currently blending water that marginally meets nitrate MCL. System needs more capacity.	County of Tulare received CDPH Prop 84 Planning Grant for Yettem and Seville. An intertie with Seville water system is being investigated in this planning process.							

Notes:

C: Community Water System

NTNC: Non-Transient, Non-Community Water System

MHP: MHP

SD: School District

USD: Unified School District

SR2: Fresno/Clovis and Surrounding Areas						Water System			Sewer System			Storm Water and Drainage		Flooding Problems	
Water System	Type	Area Type	School District	Water Provider	Outreach Notes	Type of System	Needs	Notes	Have	Needs	Notes	Have	Need	Have	Needs
William Hopkins WS		Community		SWS	Efforts not successful	Small WS serve maybe 12 connections.		Thought to be within Easton CSD boundaries.	probably private septic						
Woodward Bluffs MHP	C	MHP				Private well	No problems reported		unknown				Unknown		Unknown
Wowona Middle	C	School	Fresno USD	Fresno City DPU	Internet										

Notes:

- C: Community Water System
- NTNC: Non-Transient, Non-Community Water System
- MHP: Mobile Home Park
- SD: School District
- USD: Unified School District

SR3: Western Fresno County						Water System			Sewer System			Storm Water and Drainage		Flooding Problems	
Water System	Type	Area Type	School District	Water Provider	Outreach Notes	Type of System	Needs	Notes	Have	Needs	Notes	Have	Need	Have	Needs
Kamm Ranch Company		Farm Labor Housing			Efforts Not Successful										
Lanare CSD	C	Community		Receiver for CSD- Cal Water		Small Water System	Arsenic above MCL; can't afford treatment plant	Should receive Prop 84 Funding Agreement for Feasibility Study June 2013. Should also be receiving Funding Agreement for Prop 84, Part 1 Emergency Funding to provide interim water for up to 3 years June 2013.	Individual septic systems	Residents report gray water running onto ground			Unknown		Unknown
Las Deltas Mutual Water System	C	Community		Las Deltas Mutual WS		Small Water System	failing infrastructure	Funding Agreement awarded to consolidate with City of Firebaugh. Discussions between City and Las Deltas regarding project	Individual septic systems	No Problems at this time			No Problems at this time		No Problems at this time
Linda Vista Farms	C	Farm Labor Housing				Surface water	Uranium above MCL	Labor Camp, approx 20 units. Doing own investigation regarding options. LOI submitted January 2013. Receiving Prop 84 Part 1 Emergency Funding to provide interim water for up to 3 years June 2013.		unknown			Unkown		Unknown
Maddox Dairy		Farm Labor Housing			Efforts not Successful										
Marc High		School	Caruthers USD	Caruthers CSD					Caruthers CSD				No problems noted		
Perry Colony AKA La Arboleda (near Raisin City)		Community		??? Private?		Private wells.	Suspected high percentage exceed MCLs including arsenic	New well in Perry Colony which could become second well for Raisin City if connected 2) Annexation of PC to RC FCSA	Individual Septic systems	1-Consider a project that would include RC to PC together 2- Possible connection with Caruthers ww system					
Pershing High (cont)	NTNC	School	Central USD		Efforts Not Successful										
Raisin City	C	Community		Fresno County CSA # 43		Community WS- one well	Has only 1 source of water	New well in Perry Colony which could become second well for Raisin City if connected 2) Annexation of PC to RC FCSA	Individual Septic systems	Problems with septic systems. Need community wide sewer system	Concern - adding WW rates on top of increasing drinking water rates.		No problems noted		No problems noted
Raisin City Elementary School	C	School	Raisin City Elem	FCSA # 43		See Raisin City			Septic system	Unknown	Supportive of and interested in working with community to address needs.		No problems noted		No problems noted
Rau Dairy, Fred	C	Farm Labor Housing			Efforts not successful										
Rio Del Rey High (cont)		School	Golden Plains USD	San Joaquin?	Efforts Not Successful	City of San Joaquin? CA1010034									
Riverdale Adult School		School	Riverdale USD	Riverdale PUD?	Efforts Not Successful										
Riverdale Community Day School		School	Riverdale USD	Riverdale PUD?	Efforts Not Successful										
Riverdale Elem		School	Riverdale USD	Riverdale PUD?	Efforts Not Successful										
Riverdale HS		School	Riverdale USD	Riverdale PUD?	Efforts Not Successful										
Riverdale PUD	C	Community		Riverdale PUD		Community WS	Arsenic above MCL	2013, which determined DAC status for funding.	WW treatment facility	working to improve and increase capacity	MHI which determined DAC status for funding.		No Problems Noted		No Problems Noted
Ruby's Valley Care Home F (old name=Valley Care & Guidance)	C	Convalescent			Efforts not Successful		updating, possible need of additional well. Underground WS needs updated within the City.		WW treatment facility	Older sections of underground SS needs updating.		Have storm system	Need addition of an underground system in older sections of City which would tie into existing system		Some flooding in small areas in older sections of the City

SR4: Eastern Fresno County						Water System			Sewer System			Storm Water and Drainage		Flooding Problems	
Water System	Type	Area Type	School District	Water Provider	Outreach Notes	Type of System	Needs	Notes	Have	Needs	Notes	Have	Need	Have	Needs
Alice Manor	C	Convalescent			Didn't want to give email. No info given; Non DAC										
Alta Elem	NTNC	School	Kings Canyon USD						New septic 2011-2012 school year				No Problems Noted		No problems noted
Bigger S Ponderosa Trailer Pk	NTNC	MHP		Bigger S Ponderosa Trailer Pk	Efforts not successful; Non DAC										
Centerville		Community			Efforts not successful										
Bowles	private wells	Community		NA	Outreach to involve residents. No interest. Non DAC residential	Individual private wells		Pacific Union School District (K-8 school) and Manning Gardens Conv Home located within this residential area. Schools and Home are DAC. Residential area are Non-DAC	Individual septic systems	unknown			No problems noted		No problems noted
Centerville Elem School	NTNC	School	Sanger USD			Private well	A better solution. School located too far in the country to connect.	Facility director challenged with the small school operating own PWS.	Septic system	Located too far in the country to connect.			No problems noted		No problems noted
Clay Joint Elem School	NTNC	School	Clay Joint Elementary School District			Private well. Ok, doing fine			No problems noted	No problems noted			No problems noted		No problems noted
Conejo Middle School		School	Laton USD		Efforts not successful										
Clarín Apartments		Community			Efforts not successful										
Cove Island Resort	NC	Unknown		probably private	Efforts not successful; Non DAC										
Cumorah Knolls		Community			Did not contact. Non DAC										
Del Rey CSD	C	Community		Del Rey CSD		Three older wells	Starting issues: 123 TCP-some. Low levels demands increasing due to growth w/Paramont Packing Houses		Waste Water System	Could use some improvements			No problems noted		No problems noted
Del Rey Elem	NC	School	Sanger USD	Sanger Water Treatment Plant		City WS			City sewer	No problems noted			No problems noted		No problems noted
Doyals MHP	C	MHP		privately owned MHP	Efforts not successful										
Driftwood MHP	NC	MHP			Efforts not successful; Non DAC										
Fairmont Elem School	NTNC	School	Sanger USD			Nitrate issue	Connection to CSA 10-Cumorch Knolls which is not a DAC; SFR Planning funded; Working on agreement with County now		Septic System	No problems noted			No problems noted		No problems noted
Fowler, City of	C	City		Fowler Public Works	City Council supportive of Pilot Project intent. Indicated strong interest in attending meetings.	City WS	No problems indentified		S.K.F. Sanitation District (Selma, Kingsburg, Fowler)	No problems noted			No problems noted		No problems noted

SR4: Eastern Fresno County						Water System			Sewer System			Storm Water and Drainage		Flooding Problems	
Water System	Type	Area Type	School District	Water Provider	Outreach Notes	Type of System	Needs	Notes	Have	Needs	Notes	Have	Need	Have	Needs
Riverbend MHP & RV Park	C	MHP			Non DAC	Water meets all standards, 2 wells - Sandy Point shares with them		No charge for sewer or water to residents. Did not want to discuss financials.		No problems noted	No charge for sewer to residents		No problems noted		No problems noted
Riverview School	NTNC	School	Kings Canyon USD		Efforts not successful										
Sandy Point MHP	C	MHP			Non DAC	Assistant manager says no problems. Shares well/s with Riverbend MHP	Resident - Have been given "don't drink water notices in past"	25 units	Septic system	Residents report septic sometimes "leaks onto road"		No storm drainage			Roads poor condition; Some flooding reported
Selma Christian School	NA	School	Private	Private home school	No Data collected	Private home - private school			private home						
Shasta MHP	?	MHP													
Sherwood Forest MHP	C	MHP			Non DAC		No problems reported	Very nice area. No needs; but interested in information.		No problems reported			No problems noted		No problems noted
Terry School	NTNC	School	Selma USD			No problems noted; own well. Water contracted to test.			Interviewee thinks City sewer	No problems noted			No problems noted		No problems noted
Tract 1199 Water System	C	Community			Non DAC	Has 10 connections. Reported that "residents take turns managing it."	Has had coliforms; current status unknown		Small water system	No problems noted			No problems noted		No problems noted
Viking Trailer Park	NC	MHP			Efforts not successful; Non DAC										
Wildwood Island		Community			Did not contact. Non DAC										
Zonneveld Dairy	C	Farm Labor Housing		Zonneveld Dairy		Currently exceeds MCL for arsenic	Blending wells 1 and 2. Planning a new well.		unknown	No problems noted			No problems noted		No problems noted

Notes:

- NC: Non-Community Water System
- C: Community Water System
- NTNC: Non-Transient, Non-Community Water System
- MHP: MHP
- SD: School District
- USD: Unified School District

SR5: Northern Kings County						Water System			Sewer System			Storm Water and Drainage		Flooding Problems	
Water System	Type	Area Type	School District	Water Provider	Outreach Notes	Type of System	Needs	Notes	Have	Needs	Notes	Have	Need	Have	Needs
Armona Community Services District	C	Community		Armona Community Services District		Water system supply exceeds arsenic MCL	Pilot test well for arsenic. SWS requesting income survey of the service area in order to determine a more accurate median household income (MHI).	(In process)		None at this time		N/A		N/A	
Delta View Joint Elementary		School	Delta View Joint Elementary				Arsenic issue			None at this time		NA	none at this time	NA	No problems noted
Gardenside Elementary School		School	Gardenside Elementary School				Arsenic issue	Interested in funding		Unknown		unknown	unknown		unknown
Hanford Christian School	NTNC	School	Hanford Christian School				Recent bacteria in system	Chlorinated system; waiting for report from county.		None at this time					
Hardwick Water Company	C	Community		Hardwick Water Company		Water system high in uranium.	SWS submitted a Prop 84 funding application to address uranium in drinking water. Funding Agreement issued to SWS to drill test well. Nolte-V5 Engineering will oversee the project and take care of bid invitation. Pre-construction meeting scheduled for 5/30/2013.	Pre-Construction Meeting scheduled for 5/30/2013		None at this time		NA		NA	
Home Garden CSD	C	Community		Home Garden CSD		Water system high in arsenic.	Several blocks of the water distribution system are old and leaking and need to be replaced.	Seeking possible funding to replace water distribution system pipe lines that are old and leaking.		None at this time		NA		NA	
Island Union School	NTNC	School	Island Union School				none at this time			Unknown		unknown	unknown		unknown
Kings River Hardwick Elem															
Kings River Hardwick Elementary		School	Kings River Hardwick Elementary				arsenic in distribution system	interested in funding		None at this time		NA	none at this time		
Kit Carson Elementary		School	Kit Carson Elementary				none at this time			None at this time		NA	none at this time	NA	No problems noted
Lakeside Elementary School	NTNC	School	Lakeside Elementary SD			Consistent bacterial problems in water system. Lakeside Elementary Service	Install a new well.	Kelly Grangler is taking care of system. Brewer said they have no problems and don't plan on submitting funding applications at this point. Not cooperative) 2-24-12 HP							
Lemoore Mobile Home Park (LMHP)	C	Mobile Home Park		Lemoore MHP		LMHP notified by County that water system does not meet standards.	Rather than treatment decision was to consolidate w/the City of Lemoore CA1610005	Waiting for preliminary report from City of Lemoore.		Connect to City.	None at this time; however, may be problems in future due to limited capacity. Do not have enough land capacity; only has easement adjacent to property. If not, then would be in trouble according to owner.	(unknown) Possibly could use more drainage.	(unknown)		No problems noted
Pioneer Primary School		School	Pioneer Primary School				arsenic in distribution system			None at this time		NA	none	NA	No problems noted
Stratford PUD	C	Community		Stratford Public Utility District			Many issues with water system.	Searching for funding source		Many issues with wastewater system		More drainage needed.	state funding	NA	No problems noted

Notes:

C: Community Water System

NTNC: Non-Transient, Non-Community Water System

CSD: Community Service District

